



last 2 yrs of Pineview data

Aaron Setran to: Rich Campbell

Cc: David Albright

12/06/2012 02:49 PM

From: Aaron Setran/R9/USEPA/US
To: Rich Campbell/R9/USEPA/US@EPA,
Cc: David Albright/R9/USEPA/US@EPA

History: This message has been replied to.

Rich:

Attached are spreadsheets which summarize the Pineview monthly monitoring reports (for the last 24 months) for both wastewater trtmt and disposal systems on site (Systems A and B). You can see from the data that both ww trtmt systems, for the last 24 months, fail to meet permit effluent conditions for BOD, SS and Nitrogen. In addition, groundwater monitoring samples show that Disposal Field A is noncompliant with the MCL for Nitrogen, and has been so for all 24 months; it is also noncompliant with the MCL for F. coliform, but only periodically.

Most alarming is the ineffectiveness of the trtmt units, as indicated by the low (and sometimes negative) values calculated for removal efficiencies.



PineviewFieldAdata.Dec2012.xlsx PineviewFieldBdata.Dec2012.xlsx

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

<http://www.epa.gov/region9/water/groundwater/index.html>
<http://www.epa.gov/region9/water/groundwater/uic-hicesspools.html>
<http://www.epa.gov/region9/water/groundwater/injection-wells-register.html>